

STATE OF VERMONT
PUBLIC SERVICE BOARD

CPG No. NM-58

In Re: Petition of Vincent and Eileen Illuzzi)
requesting a certificate of public good for an)
interconnected net metered wind-generated)
electrical power system located on petitioner's)
property on Ridge Hill Drive in Derby, Vermont)

Entered: 7/1/2002

CERTIFICATE OF PUBLIC GOOD ISSUED
PURSUANT TO 30 V.S.A. SECTION 248

IT IS HEREBY CERTIFIED that the Public Service Board of the State of Vermont ("Board") this day found and adjudged that the net metering system proposed by Vincent and Eileen Illuzzi ("Applicants") in Derby, Vermont, will promote the general good of the State, subject to the following conditions:

1. Operation and maintenance of the net metering system shall be in accordance with the plans and evidence submitted in this proceeding. Any material or substantial change in the project is prohibited without prior Board approval.
2. The net metering system shall comply with applicable existing and future statutory requirements and Board Rules and Orders.
3. This Certificate shall not be transferred without prior approval of the Board. The holder of this Certificate must notify the Board, the Vermont Department of Public Service, and the appropriate electric utility of any proposed transfer of the Certificate.
4. At a 300-foot radius from the base of the tower, the sound level from the turbine shall not exceed 50dB. If an interested party requests a sound test and the Board agrees it is necessary to have sound testing done, the Applicant shall pay the first \$500 in costs for a sound study, the balance to be paid by the person(s) initiating the request.

DATED at Montpelier, Vermont, this 1st day of July, 2002.

s/Michael H. Dworkin

)

) PUBLIC SERVICE

)

s/David C. Coen

)

BOARD

)

)

OF VERMONT

s/John D. Burke

)

OFFICE OF THE CLERK

Filed: July 1, 2002

Attest: s/Susan M. Hudson

Clerk of the Board

NOTICE TO READERS: This decision is subject to revision of technical errors. Readers are requested to notify the Clerk of the Board (by e-mail, telephone, or in writing) of any technical errors, in order that any necessary corrections may be made. (E-mail address: Clerk@psb.state.vt.us)